



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-6945

NOTED:

ACCREDITATION NO. 065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6707645	Sample Source	MORORPOOL FAUCET
Control Number		Address	HDC COMPOUND STA MESA MANILA
Laboratory Number	4390		
Submitted by	PUP-I TECH CAMPUS		
Date of Collection	AUGUST 29, 2017		
Time of Collection	9:30 AM	Physical Characteristics	CLEAR
Time Received	10:35 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Lab. Receipt Number
 Submitted by
 Date of Collection
 Time of Collection

CERTIFIED CORRECT:

Ey. Bondoc

EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

NOTED:

M. P. SANTOS, MD, FPSP
 MARIA LOURDES P. SANTOS, MD, FPSP
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO. 065

MICROBIOLOGICAL EXAMINATION OF WATER

(Multiple Tube Fermentation Technique)

Official Receipt Number	6707645	Sample Source	COLLEGE MEDICAL CLINIC
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	4391		
Submitted by	PUP		
Date of Collection	AUGUST 29, 2017		
Time of Collection	8:50 AM	Physical Characteristics	CLEAR
Time Received	10:35 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

CERTIFIED CORRECT:

E. J. Bondoc

EMELYN J. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

NOTED:

MEL SANTOS MD
 MARIA LOURDES M. ALONSO-SANTOS MD, FPSP
 Pathologist
 Officer-In-Charge
 LIC. NO: 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

NOTED: **MICROBIOLOGICAL EXAMINATION OF WATER**
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6707645	Sample Source	HASMIN MEDICAL FAUCET
Control Number		Address	VALENCIA ST STA MESA M.H. DEL PILAR CAMPUS HASMIN
Laboratory Number	4392		
Submitted by	PUP-HASMIN CAMPUS		
Date of Collection	AUGUST 29,2017		
Time of Collection	10:05 AM	Physical Characteristics	CLEAR
Time Received	10:35 AM		

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	Less than 1.1 or 0
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number
 Submitted by
 Date of Collection
 Time of Collection
 Time Received
 NOTED:
MESANTOS MD
 MARIA LOURDES P. MESANTOS MD, FPSP
 LIC# 78301
 Pathologist
 Officer-in-Charge
 LIC. NO. 7830

CERTIFIED CORRECT:
E. Bondoc
EMELYN T. BONDOR, RMT
 Medical Technologist IV
 LIC. NO. 13729



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street, Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO: 065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6707545	Sample Source	COC-PUP MED. CLINIC
Control Number		Address	COC-NDC-PUP
Laboratory Number	4393		
Submitted by	PUP-COC CAMPUS		
Date of Collection	AUGUST 29, 2017		
Time of Collection	9:30 AM	Physical Characteristics	CLEAR
Time Received	10:35 AM		

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number: 4393
 Submitted by: PUP-COC CAMPUS
 Date of Collection: AUGUST 29, 2017
 Time of Collection: 9:30 AM

CERTIFIED CORRECT:

E.T. Bondoc

EMELYN T. BONDQC, RMT
 Medical Technologist IV
 LIC. NO. 13729

NOTED:

MPSANTOS MD
 MARIA LOURDES M. P. SANTOS, MD, EPSP
 LIC. NO. 7830
 Pathologist
 Officer-in-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quirica Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6707645	Sample Source	DRINKING FOUNTAIN DIRECTLY CONNECTED TO-"TANKEE"
Control Number		Address	PUP-LHS- MABINI CAMPUS STA MESA MANILA
Laboratory Number	4394		
Submitted by	PUP-LAB HIGH CAMPUS		
Date of Collection	AUGUST 29,2017		
Time of Collection	8:45 AM	Physical Characteristics	CLEAR
Time Received	10:35 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number
 Submitted by PUP
 Date of Collection
 Time of Collection

CERTIFIED CORRECT:

E.T. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

NOTED:

Maria Lourdes
MRS. MARIA LOURDES ROSARIO SANTOS, MD, FPSP
 Pathologist
 Officer-in-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6707645	Sample Source	FAUCET AT PARKING LOT A AT THE BACK OF ME STEAM LAB.
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	4389		
Submitted by	NDC-CEA CAMPUS (PUP)		
Date of Collection	AUGUST 29,2017		
Time of Collection	9:25 AM	Physical Characteristics	CLEAR
Time Received	10:35 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number	
Submitted by	
Date of Collection	
Time of Collection	

CERTIFIED CORRECT:

E.T. Bondoc

EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

NOTED:

MARIA ROSALEEN PINEDA SANTOS, MD, FPSP
 Lic. No. 7830
 Pathologist
 Officer-in-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

NOTED:

ACCREDITATION NO.965

MICROBIOLOGICAL EXAMINATION OF WATER

(Multiple Tube Fermentation Technique)

Official Receipt Number	6707645	Sample Source	MORORPOOL FAUCET
Control Number		Address	HDC.COMPOUND STA MESA MANILA
Laboratory Number	4390		
Submitted by	PUP-ITECH CAMPUS		
Date of Collection	AUGUST 29,2017		
Time of Collection	9:30 AM	Physical Characteristics	CLEAR
Time Received	10:35 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number		CERTIFIED CORRECT:
Submitted by		<i>E. Bondoc</i>
Date of Collection		EMELYN T. BONDOC, RMT
Time of Collection		Medical Technologist IV
Time Received		LIC. NO. 13729

MARIA LOURDES BONDOS SANTOS, MD, FPSP
 LIC. NO. 7830
 Pathologist
 Officer-In-Charge
 LIC. NO: 7830





POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6707645	Sample Source	COLLEGE MEDICAL CLINIC
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	4391		
Submitted by	PUP		
Date of Collection	AUGUST 29, 2017		
Time of Collection	8:50 AM	Physical Characteristics	CLEAR
Time Received	10:35 AM		

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

NOTED: _____

CERTIFIED CORRECT:

E. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

MELISSA M. SANTOS MD
 MARIA LOURDES P. PINEDA-SANTOS MD, FPSP
 LIC. NO. 78301
 Pathologist
 Officer-in-Charge
 LIC. NO: 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6707645	Sample Source	HASMIN MEDICAL FAUCET
Control Number		Address	VALENCIA ST STA MESA M.H. DEL PILAR CAMPUS HASMIN
Laboratory Number	4392		
Submitted by	PUP-HASMIN CAMPUS		
Date of Collection	AUGUST 29,2017		
Time of Collection	10:05 AM	Physical Characteristics	CLEAR
Time Received	10:35 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number: _____
 Submitted by: PUP HASMIN
 Date of Collection: AUGUST 29, 2017
 Time of Collection: 10:05 AM
 Time Received: 10:35 AM

CERTIFIED CORRECT:
Eg. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

NOTED:
MERSANTOS, MD
 MARIA LOURDES M. MERSANTOS, MD, FPSP
 Pathologist
 Officer-in-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street, Sta. Cruz, Manila
 Telephone Number: 711-69-45

ACCREDITATION NO. 065

MICROBIOLOGICAL EXAMINATION OF WATER

(Multiple Tube Fermentation Technique)

Official Receipt Number	6707645	Sample Source	COC-PUP MED. CLINIC
Control Number		Address	COC-NDC -PUP
Laboratory Number	4393		
Submitted by	PUP-COC CAMPUS		
Date of Collection	AUGUST 29, 2017		
Time of Collection	9:30 AM	Physical Characteristics	CLEAR
Time Received	10:35 AM		

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number: 4393
 Submitted by: PUP-COC CAMPUS
 Date of Collection: AUGUST 29, 2017
 Time of Collection: 9:30 AM

NOTED: _____
MARIA LOURDES L. PINEDA SANTOS, MD, FPSP
 Pathologist
 Officer-in-Charge
 LIC. NO. 7830

CERTIFIED CORRECT:
E.T. Bondoc
EMELYN T. BONDLOC, RMT
 Medical Technologist IV
 LIC. NO. 13729



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER

(Multiple Tube Fermentation Technique)

Official Receipt Number	6707645	Sample Source	DRINKING FOUNTAIN DIRECTLY CONNECTED TO-"TANKEE"
Control Number		Address	PUP-LHS- MABINI CAMPUS STA MESA MANILA
Laboratory Number	4394		
Submitted by	PUP-LAB HIGH CAMPUS		
Date of Collection	AUGUST 29,2017		
Time of Collection	8:45 AM	Physical Characteristics	CLEAR
Time Received	10:35 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number: _____
 Submitted by: PUP
 Date of Collection: _____
 Time of Collection: _____
 NOTED: _____

CERTIFIED CORRECT:
E. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

MRS. MARIA LOURDES B. SANTIAGO-SANTOS, MD, FPSP
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines

City of Manila

MANILA HEALTH DEPARTMENT

Division of Public Health Laboratory

208 Quiricada Street Sta. Cruz, Manila

Telephone Number 711-69-45

NOTE:

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER

(Multiple Tube Fermentation Technique)

Official Receipt Number: 6414957	Sample Source FAUCET
Control Number	Address ANONAS ST STA MESA, MANILA
Laboratory Number 2491	
Submitted by PUP- MABINI CAMPOS	
Date of Collection MAY 15, 2017	Physical Characteristics CLEAR
Time of Collection 8:50 AM	
Time Received 9:40 AM	

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number
 Submitted by PUP- MABINI CAMPOS
 Date of Collection
 Time of Collection
 Time Received

CERTIFIED CORRECT:

E.T. Bondoc

EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

MARIA LOURDESE PINEDA-SANTOS, MD, FPSP

Pathologist
 Officer-In-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

NOTED: ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6430857	Sample Source	DRINKING FOUNTAIN
Control Number		Address	PUP ANONAS ST STA MESA MANILA
Laboratory Number	2493		
Submitted by	PUP- LHS		
Date of Collection	MAY 15, 2017		
Time of Collection	8:35 AM	Physical Characteristics	CLEAR
Time Received	9:40 AM		

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number: _____
 Submitted by: _____
 Date of Collection: _____
 Time of Collection: _____
 Time Received: _____

CERTIFIED CORRECT:
E. T. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

M. P. SANTOS, MD
 MARIA LOURDES P. PALEDA-SANTOS, MD, FPSP
 LIC. NO. 7830
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

NOTED:

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER

(Multiple Tube Fermentation Technique)

Official Receipt Number	6414957	Sample Source	
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	2490		
Submitted by	PUP-COC		
Date of Collection	MAY 15, 2017		
Time of Collection	7:30 AM	Physical Characteristics	CLEAR
Time Received	9:40 AM		

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Submitted by: PUP
 Date of Collection: MAY 15, 2017
 Time of Collection: 7:30 AM
 Time Received: 9:40 AM

CERTIFIED CORRECT:

E. T. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

NOTED:
Maria Lourdes E. Pineda-Santos
MARIA LOURDES E. PINEDA-SANTOS, MD, FPSP
 Pathologist
 Officer-in-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
 MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER

(Multiple Tube Fermentation Technique)

Official Receipt Number	6414957	Sample Source	HASMIN FAUCET
Control Number		Address	MEDICA CLINIC STA MESA MANILA
Laboratory Number	2489		
Submitted by	PUP-MH DEL PILAR CAMPOS STA MESA		
Date of Collection	MAY 15, 2017		
Time of Collection	8:05 AM	Physical Characteristics	CLEAR
Time Received	9:40 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Submitted by: PUP-MH DEL PILAR CAMPOS STA MESA

Date of Collection: MAY 15, 2017

Time of Collection: 8:05 AM

Time Received: 9:40 AM

NOTED: *[Signature]*

MEPSANTOS, MD
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830

CERTIFIED CORRECT: *[Signature]*
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

NOTED:

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6414957	Sample Source	MOTORPOOL FAUCET
Control Number		Address	NDC COMPOUND STA MESA MANILA
Laboratory Number	2488		
Submitted by	PUP-INSTITUTE OF TECHNOLOGY		
Date of Collection	MAY 15, 2017		
Time of Collection	8:40 AM	Physical Characteristics	CLEAR
Time Received	9:40 AM		

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Submitted by: _____
 Date of Collection: _____
 Time of Collection: _____
 Time Received: _____

CERTIFIED CORRECT:

Emelyn T. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

Maria Lourdes M. Santos
MARIA LOURDES M. SANTOS, MD, FPSP
 Pathologist
 Officer-in-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6414957	Sample Source	CEA FAUCET
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	2492		
Submitted by	PUP-CEA CAMPOS		
Date of Collection	MAY 15, 2017		
Time of Collection	9:00 AM	Physical Characteristics	CLEAR
Time Received	9:40 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number: _____
 Date of Collection: _____
 Time of Collection: _____
 Time Received: _____
 NOTED: _____

CERTIFIED CORRECT:

E.T. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

Maria Lourdes Pineda Santos
MARIA LOURDES PINEDA-SANTOS, MD, FPSP
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
 MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.055

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6124223	Sample Source	
Control Number		Address	VALENCIA ST STA MESA MANILA
Laboratory Number	852		
Submitted by	PUP- HASMIN		
Date of Collection	FEBRUARY 13, 2017		
Time of Collection	8:50 AM	Physical Characteristics	CLEAR
Time Received	10:30 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number
 Submitted by
 Date of Collection
 Time of Collection
 Time Received

CERTIFIED CORRECT:

E.T. Bondoc

EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

M.P. SANTOS, MD
 LIC. NO. 7830
 MARIA LOURDES E. PINEDA-SANTOS, MD, FPSP
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830

<1.1

MPN/100 ml Total Coliform
 MPN/100 ml Fecal Coliform



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
 MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number: 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER

(Multiple Tube Fermentation Technique)

Official Receipt Number	6124223	Sample Source	MOTORPOOL FAUCET
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	857		
Submitted by	PUP I-TECH		
Date of Collection	FEBRUARY 13, 2017		
Time of Collection	9:00 AM	Physical Characteristics	CLEAR
Time Received	10:30 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number
 Submitted by
 Date of Collection
 Time of Collection
 Time Received

CERTIFIED CORRECT:

Ej. Bondoc
 EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

NOTED:
MEP SANTOS, MD
 MARIA LOURDEZ PINTO-SANTOS, MD, FPSP
 Pathologist
 Officer-in-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
 MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER

NOTED.

(Multiple Tube Fermentation Technique)

Official Receipt Number	6124223	Sample Source	
Control Number		Address	ANONA ST SAMPALOC MANILA
Laboratory Number	856		
Submitted by	PUP- COC		
Date of Collection	FEBRUARY 13, 2017		
Time of Collection	8:50 AM	Physical Characteristics	CLEAR
Time Received	10:30 AM		

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number: 856
 Submitted by: PUP- COC
 Date of Collection: FEBRUARY 13, 2017
 Time of Collection: 8:50 AM
 Time Received: 10:30 AM
 NOTED.

CERTIFIED CORRECT:

Eg Bondoc
 EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

MEPSANTOS, MD
 MARIA LOURDES L. LONEDA S. SANTOS, MD, FPSP
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6124223	Sample Source	FAUCET
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	855		
Submitted by	PUP- MABINI CAMPUS		
Date of Collection	FEBRUARY 13, 2017		
Time of Collection	8:40 AM	Physical Characteristics	CLEAR
Time Received	10:30 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number
 Submitted by
 Date of Collection
 Time of Collection
 Time Received

NOTED

MARIA LOURDES E. PINEDA-SANTOS, MD, FPSP
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830

CERTIFIED CORRECT:
E. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
 MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER

(Multiple Tube Fermentation Technique)

Official Receipt Number	6124223	Sample Source	CEA CLINIC FAUCET
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	854		
Submitted by	PUP-CEA		
Date of Collection	FEBRUARY 13, 2017		
Time of Collection	9:00 AM	Physical Characteristics	CLEAR
Time Received	10:30 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water. (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number
 Submitted by
 Date of Collection
 Time of Collection
 Time Received

CERTIFIED CORRECT:

Ey. Bondoc
 EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

MARIA LOURDES ESPINOSA SANTOS, MD, FPSP
 Pathologist
 Officer-in-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER

(Multiple Tube Fermentation Technique)

Official Receipt Number	6124223	Sample Source	FAUCET IN MAIN TANK
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	853		
Submitted by	PUP- LABORATORY HIGH SCHOOL		
Date of Collection	FEBRUARY 13, 2017		
Time of Collection	9:00 AM	Physical Characteristics	CLEAR
Time Received	10:30 AM		

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	Less than 1.1 or 0
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Submitted by PUP- LABORATORY HIGH SCHOOL
 Date of Collection
 Time of Collection
 Time Received

CERTIFIED CORRECT:

Ey. Bondoc

EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

MARIA LOURDES E. PINEDA-SANTOS, MD, FPSP
 LIC# 78301
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

NOTED: **MICROBIOLOGICAL EXAMINATION OF WATER**
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6915681	Sample Source	FAUCET
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	5681		
Submitted By	PUP-LHS		
Date of Collection	NOVEMBER 27, 2017		
Time of Collection	9:40 AM	Physical Characteristics	CLEAR
Time Received			

RESULT ANALYSIS

Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)

	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number		CERTIFIED CORRECT: EMELYN T. BONDOC, RMT Medical Technologist IV LIC. NO. 13729
Submitted By		
Date of Collection		
Time of Collection		
Time Received		

 MARIA LOURDES P. PINEDA-SANTOS, MD, FPSP Pathologist Officer-in-Charge LIC. NO. 7830	
Total Coliform	<1.1



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

NOTED: **MICROBIOLOGICAL EXAMINATION OF WATER**
 (Multiple-Tube Fermentation Technique)

Official Receipt Number: 6915681	Sample Source FAUCET
Control Number	Address ANONAS ST STA MESA MANILA
Laboratory Number 5681	
Submitted By PUP-LHS	
Date of Collection NOVEMBER 27,2017	
Time of Collection 9:40 AM	Physical Characteristics CLEAR
Time Received	

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number
 Submitted By
 Date of Collection
 Time of Collection
 Time Received

CERTIFIED CORRECT:

E.T. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

MARIA LOURDES E. PINEDA SANTOS, MD, FPSP
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6915681	Sample Source	PARKING A, FAUCET
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	5683		
Submitted By	PUP-CEA		
Date of Collection	NOVEMBER 27, 2017		
Time of Collection	9:20 AM	Physical Characteristics	CLEAR
Time Received			

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number: _____
 Submitted By: _____
 Date of Collection: _____
 Time of Collection: _____
 Time Received: _____

CERTIFIED CORRECT:

E.T. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

MARIA LOURDES RINEDA SANTOS, MD, FPSP
 Pathologist
 Officer-in-Charge
 LIC. NO. 7830



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
 COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number, 711-69-45

ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6915681	Sample Source	MOTORPOOL FAUCET
Control Number		Address	ANONAS ST STA MESA MANILA
Laboratory Number	5684		
Submitted By	INSITUTE OF TECHNOLOGY PUP		
Date of Collection	NOVEMBER 27,2017		
Time of Collection	9:10 AM	Physical Characteristics	CLEAR
Time Received			

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number
 Submitted By
 Date of Collection
 Time of Collection
 Time Received

NOTED:

MARIA LOURDES R. BINSO SANTOS, MD, FPSP
 Lic. 7830
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830

CERTIFIED CORRECT:

E. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729



POLYTECHNIC UNIVERSITY OF THE PHILIPPINES
COLLEGE OF ENGINEERING
COMPUTER ENGINEERING DEPARTMENT



Republic of the Philippines
 City of Manila
MANILA HEALTH DEPARTMENT
 Division of Public Health Laboratory
 208 Quiricada Street Sta. Cruz, Manila
 Telephone Number 711-69-45

NOTED: ACCREDITATION NO.065

MICROBIOLOGICAL EXAMINATION OF WATER
 (Multiple Tube Fermentation Technique)

Official Receipt Number	6915681	Sample Source	FAUCET
Control Number		Address	VALENCIA ST STA MESA MANILA
Laboratory Number	5686		
Submitted By	PUP M.H. DEL PILAR CAMPUS		
Date of Collection	NOVEMBER 27, 2017		
Time of Collection	8:20 AM	Physical Characteristics	CLEAR
Time Received			

RESULT ANALYSIS			
Total Coliform	Fecal Coliform	Heterotrophic Plate Count cfu/ml	Remarks
<1.1	<1.1	NONE	PASSED

Philippine National Standards for Drinking Water (PNSDW)		
	Refilling Station	Public Water Sample
MPN/100 ml Total Coliform	Less than 1.1 or 0	
MPN/100 ml Fecal Coliform	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count	Less than 500 cfu/ml	

Laboratory Number
 Submitted By: PUP
 Date of Collection
 Time of Collection
 Time Received

CERTIFIED CORRECT:

Emelyn T. Bondoc
EMELYN T. BONDOC, RMT
 Medical Technologist IV
 LIC. NO. 13729

NOTED:
MERSANTOS MD
MARIA LOURDES TORIBIO SANTOS MD, FPSP
 Pathologist
 Officer-In-Charge
 LIC. NO. 7830